

Summary of Test Results

High Point School of Bergen County

In compliance with Department of Education mandates, all NJ schools shall be subject to water testing and to subsequently post the results of that testing thusly:

Date of most recent lead sampling analysis	9/1/2021
Did the most recent sampling discover an exceedance of the permissible lead and copper action levels in any water sample collected from the facility?	Yes <u>Detail:</u> "Results of most first-draw samples analyzed were below the Lead and Copper Rule action level of 15 ppb." Out of the sampling from 14 sinks and water fountains in the facility: 5 first-draw samples were found to be above the 15 ppb level; 4 of the associated flush samples were below 15 ppb; and 1 associated flush sample was above 15 ppb.
Recommended actions	<ul style="list-style-type: none">• Positive outlets put out of commission & flushed daily or weekly until retesting• Continue to conduct further evaluation, flushing & testing• Repeat full building testing on an annual basis
Consequent actions immediately taken by school	<ul style="list-style-type: none">• Full cooperation & collaboration with testing agency, Omega Environmental Services, Inc.• Implementation of above-listed recommendations• Nestlé® PureLife® purified water coolers placed in every classroom of the school & in common areas• Signs posted in all bathrooms instructing users that sink water is not for drinking• Staff & students clearly instructed, both verbally & in writing, that the purified bottled water provided on campus is the source of drinking water at school

For original source report, see next page.

For Questions:

Cindy Pulido, Supervisor

973-574-0344

cpulido@highpointschool.com



LEAD IN POTABLE WATER SCREENING REPORT

INVESTIGATION FOR: Valentina Baldessarre
Archdiocese of Newark
171 Clifton Avenue
P.O. Box 9500
Newark, NJ 07104

SITE INVESTIGATED: St. Joseph/High Point School
40 Spring Street
Lodi, NJ 07644

ASSESSMENT BY: Sarah Hutchins
Omega Environmental Services, Inc.
280 Huyler Street
South Hackensack, NJ 07606

INVESTIGATION
CONDUCTED: 9/1/2021

DATE OF REPORT: 10/15/2021

(Omega Project # 21-26072)

TABLE OF CONTENTS

EXECUTIVE SUMMARY/PROJECT OVERVIEW

1. RESULTS TABLE
2. SAMPLING METHODOLOGY
3. DISCUSSION OF RESULTS
4. RECOMMENDATIONS

Appendices:

A. Laboratory Analytical Reports

EXECUTIVE SUMMARY:

The Archdiocese of Newark requested representative lead in water testing of potable water outlets at St. Joseph/High Point School on 40 Spring Street, Lodi, NJ, 07644.

Previous Testing (5/12/2017)

In order to assess the building water outlets, a full testing of all potable outlets was performed on May 12, 2017.

Reportedly the outlets were not flushed or used on the day of testing.

First draw and flush (30 seconds) samples were collected at 16 water fountains and sinks.

Results of most first draw samples analyzed were below the Lead and Copper Rule action level of 15 ppb. Three (3) first draw samples were above 15 ppb. The associated flush samples were below 15 ppb.

Please see report dated June 19, 2017.

Follow-up Recent Testing (9/1/2021)

In order to further assess the building water outlets a testing of representative potable outlets was performed on September 1, 2021.

Reportedly the outlets were flushed the day prior to sampling.

The following outlets were not sampled because they were not operational or were not previously flushed:

- 2nd Floor Girls Bathroom Center Sink – not operational
- 2nd Floor Girls Bathroom Right Sink – not operational
- 2nd Floor Boys Bathroom Left Sink – not operational
- 1st Floor Girls Bathroom Right Sink – not operational
- Outside Water Spigot – not operational

First draw and flush samples (30 second) were collected at 14 water fountains and sinks.

Results of most first draw samples analyzed were below the Lead and Copper Rule action level of 15 ppb. Five (5) first draw samples were above 15 ppb. Four (4) of the associated flush samples were below 15 ppb and one (1) of the associate flush samples were above 15 ppb.

See Section 3 Discussion of Results

Applicable Corrective Action

The positive outlets should not be used by students/staff but should continue to be flushed daily or weekly pending re-test.

Water Management/Plumbing Plan

No water management/plumbing plan has been created for St. Joseph/High Point School.

1 RESULTS TABLE:

Sample #	Location	1 st draw (FD) or flush (FL)	Lead	
			Results (ppb)	LCR Action Level ⁽¹⁾ (ppb)
01 FD	2 nd Floor Girls Bathroom Left Sink ✓	FD	190	15
01 FL	2 nd Floor Girls Bathroom Left Sink ✓	FL	20.6	15
02 FD	2 nd Floor Boys Bathroom Right Sink	FD	13.4	15
02 FL	2 nd Floor Boys Bathroom Right Sink	FL	NA	15
03 FD	2 nd Floor Teacher's Lounge Room Sink ✓	FD	15.7	15
03 FL	2 nd Floor Teacher's Lounge Room Sink	FL	ND	15
04 FD	2 nd Floor Teacher's Lounge Bathroom Sink	FD	3.83	15
04 FL	2 nd Floor Teacher's Lounge Bathroom Sink ✓	FL	NA	15
05 FD	1 st Floor Girls Bathroom Left Sink ✓	FD	96.1	15
05 FL	1 st Floor Girls Bathroom Left Sink	FL	3.07	15
06 FD	1 st Floor Girls Bathroom Center Sink ✓	FD	37.8	15
06 FL	1 st Floor Girls Bathroom Center Sink	FL	2.08	15
07 FD	1 st Floor Boys Bathroom Left Sink	FD	5.08	15
07 FL	1 st Floor Boys Bathroom Left Sink	FL	NA	15
08 FD	1 st Floor Boys Bathroom Right Sink	FD	9.07	15
08 FL	1 st Floor Boys Bathroom Right Sink	FL	NA	15
09 FD	1 st Floor Main Office Bathroom Sink	FD	4.53	15
09 FL	1 st Floor Main Office Bathroom Sink	FL	NA	15
10 FD	1 st Floor Nurse's Office Bathroom Sink	FD	2.55	15
10 FL	1 st Floor Nurse's Office Bathroom Sink ✓	FL	NA	15
11 FD	1 st Floor Nurse's Office Room Sink ✓	FD	23.4	15
11 FL	1 st Floor Nurse's Office Room Sink	FL	3.85	15
12 FD	Basement Girls Gym Bathroom Sink	FD	ND	15
12 FL	Basement Girls Gym Bathroom Sink	FL	NA	15
13 FD	Basement Boys Gym Bathroom Sink	FD	1.58	15
13 FL	Basement Boys Gym Bathroom Sink	FL	NA	15
14 FD	Basement Cafeteria Kitchen Sink	FD	1.04	15
14 FL	Basement Boys Gym Bathroom Sink	FL	NA	15
15	Basement Cafeteria Kitchen Sink	FD	ND	15

⁽¹⁾ EPA Lead in Copper Rule (1991) Action Level for water suppliers (municipalities and private wells) and March 2016 Newark Public Schools Lead Water Testing Sampling Plan.

FD – First Draw Sample

FL – Flush Sample (30 sec)

ND – Indicates that the analyte was not detected at the reporting limit

NA – Not Analyzed

2 SAMPLING METHODOLOGY:

First Draw Samples - Without allowing any water to spill until sample collection, samples were collected with a relatively slow flow rate in 250 mL bottles prepared with Nitric Acid (HNO₃) as a preservative.

Flush Samples – After collection of first draw samples the water was allowed to flow at a relatively slow rate for thirty second to flush the fixture and close piping. The flush samples are intended to test the plumbing further upstream from the fixture (behind walls).

The samples were packaged in a cooler and shipped to EMSL Analytical, Inc. in Cinnaminson, NJ for total lead in potable water analysis (method E200.8 IOC).

3 DISCUSSION OF RESULTS:

Five (5) first draw sample results were above 15 ppb, but four (4) associated flush samples results were below 15 ppb. One (1) of the associate flush samples was above 15 ppb. Positive first draw samples represent Lead in fixtures while ‘flush’ samples represent plumbing lines.

4 RECOMMENDATIONS:

Short term:

- Take any outlets with elevated results out of service.
- Conduct further evaluation, flushing, and testing of outlets with elevated results.

Contact Omega Environmental to discuss specific recommendations.

Long Term:

- **If additional testing shows similar results (first draw results above 15 ppb) consider replacing the spout of the fountains (may contain brass, adding to lead levels), installing filters (if practical), or fixture replacement.**
- Repeat full building testing on an annual basis. Generally, this should be performed in August prior to the start of the school season.
- Develop a Lead in Water Management Plan in accordance with the 2006 EPA 3Ts for Reducing Lead in Drinking Water in Schools.

A. Lead in Water Laboratory Reports



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Lab**

10/5/2021

**Omega Environmental Services
280 Huyler Street
South Hackensack, NJ 07606**

Phone: (201) 489-8700
Fax: (201) 489-8797

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 9/8/2021. The results are tabulated on the attached data pages for the following client designated project:

Arch of Newark/St. Joseph High Point School/21-26072

The reference number for these samples is EMSL Order #012110578. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10672, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 658-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012110578
 CustomerID: OMEG50
 CustomerPO: 21-26072
 ProjectID:

Attn: **Lab**
Omega Environmental Services
280 Huyler Street
South Hackensack, NJ 07606

Phone: (201) 489-8700
 Fax: (201) 489-8797
 Received: 9/8/2021 09:00 AM

Project: Arch of Newark/St. Joseph High Point School/21-26072

Analytical Results

Client Sample Description	01FD	Collected:	9/1/2021	Lab ID:	012110578-0001
	2nd Floor Girls Bathroom Left Sink		9:35:00 AM		
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	190 D	5.00 µg/L	9/30/2021 VD	10/1/2021 VD 08:23
Client Sample Description	01FL	Collected:	9/1/2021	Lab ID:	012110578-0002
	2nd Floor Girls Bathroom Left Sink		9:35:00 AM		
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	20.6	1.00 µg/L	10/4/2021 VD	10/4/2021 VD 16:07
Client Sample Description	02FD	Collected:	9/1/2021	Lab ID:	012110578-0003
	2nd Floor Boys Bathroom Right Sink		9:41:00 AM		
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	13.4	1.00 µg/L	9/30/2021 VD	10/1/2021 VD 08:31
Client Sample Description	03FD	Collected:	9/1/2021	Lab ID:	012110578-0005
	2nd Floor Teacher's Lounge Room Sink Mixing Valve		9:45:00 AM		
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	15.7	1.00 µg/L	9/30/2021 VD	10/1/2021 VD 00:07
Client Sample Description	03FL	Collected:	9/1/2021	Lab ID:	012110578-0006
	2nd Floor Teacher's Lounge Room Sink Mixing Valve		9:45:00 AM		
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	10/4/2021 VD	10/4/2021 VD 16:15

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 658-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012110578
 CustomerID: OMEG50
 CustomerPO: 21-26072
 ProjectID:

Attn: **Lab**
Omega Environmental Services
280 Huyler Street
South Hackensack, NJ 07606

Phone: (201) 489-8700
 Fax: (201) 489-8797
 Received: 9/8/2021 09:00 AM

Project: Arch of Newark/St. Joseph High Point School/21-26072

Analytical Results

Client Sample Description	Method	Parameter	Result	RL Units	Collected:	Prep Date & Analyst	Lab ID:	Analysis Date & Analyst
04FD 2nd Floor Teacher's Lounge Bathroom Sink					9/1/2021 9:48:00 AM		012110578-0007	
METALS								
200.8	Lead	3.83	1.00 µg/L		9/30/2021	VD	10/1/2021	VD 00:08
05FD 1st Floor Girls Bathroom Left Sink					9/1/2021 9:52:00 AM		012110578-0009	
METALS								
200.8	Lead	96.1	1.00 µg/L		9/30/2021	VD	10/1/2021	VD 00:09
05FL 1st Floor Girls Bathroom Left Sink					9/1/2021 9:52:00 AM		012110578-0010	
METALS								
200.8	Lead	3.07	1.00 µg/L		10/4/2021	VD	10/4/2021	VD 16:16
06FD 1st Floor Girls Bathroom Center Sink					9/1/2021 9:55:00 AM		012110578-0011	
METALS								
200.8	Lead	37.8	1.00 µg/L		9/30/2021	VD	10/1/2021	VD 00:11
06FL 1st Floor Girls Bathroom Center Sink					9/1/2021 9:55:00 AM		012110578-0012	
METALS								
200.8	Lead	2.08	1.00 µg/L		10/4/2021	VD	10/4/2021	VD 16:18

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 859-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012110578
 CustomerID: OMEG50
 CustomerPO: 21-26072
 ProjectID:

Attn: **Lab**
Omega Environmental Services
280 Huyler Street
South Hackensack, NJ 07606

Phone: (201) 489-8700
 Fax: (201) 489-8797
 Received: 9/8/2021 09:00 AM

Project: Arch of Newark/St. Joseph High Point School/21-26072

Analytical Results

Client Sample Description		07FD	Collected:	9/1/2021	Lab ID:	012110578-0013
		1st Floor Boys Bathroom Left Sink		9:35:00 AM		
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst	
METALS						
200.8	Lead	5.08	1.00 µg/L	9/30/2021 VD	10/1/2021 VD	00:12
Client Sample Description		08FD	Collected:	9/1/2021	Lab ID:	012110578-0015
		1st Floor Boys Bathroom Right Sink		9:35:00 AM		
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst	
METALS						
200.8	Lead	9.07	1.00 µg/L	9/24/2021 IC	9/27/2021 JW	19:08
Client Sample Description		09FD	Collected:	9/1/2021	Lab ID:	012110578-0017
		1st Floor Main Office Bathroom Sink		9:35:00 AM		
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst	
METALS						
200.8	Lead	4.53	1.00 µg/L	9/30/2021 VD	10/1/2021 VD	00:14
Client Sample Description		10FD	Collected:	9/1/2021	Lab ID:	012110578-0019
		1st Floor Nurse's Office Bathroom Sink		9:35:00 AM		
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst	
METALS						
200.8	Lead	2.55	1.00 µg/L	9/30/2021 VD	10/1/2021 VD	00:15
Client Sample Description		11FD	Collected:	9/1/2021	Lab ID:	012110578-0021
		1st Floor Nurse's Office Room Sink		9:35:00 AM		
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst	
METALS						
200.8	Lead	23.4	1.00 µg/L	9/30/2021 VD	10/1/2021 VD	00:17



EMSL Analytical, Inc.
 200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012110578
 CustomerID: OMEG50
 CustomerPO: 21-26072
 ProjectID:

Attn: **Lab**
Omega Environmental Services
280 Huyler Street
South Hackensack, NJ 07606

Phone: (201) 489-8700
 Fax: (201) 489-8797
 Received: 9/8/2021 09:00 AM

Project: Arch of Newark/St. Joseph High Point School/21-26072

Analytical Results

Client Sample Description	11FL 1st Floor Nurse's Office Room Sink	Collected:	9/1/2021 9:35:00 AM	Lab ID:	012110578-0022
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.85	1.00 µg/L	10/4/2021 VD	10/4/2021 VD 16:19
Client Sample Description	12FD BSMT Girls Gym Bathroom Sink	Collected:	9/1/2021 9:35:00 AM	Lab ID:	012110578-0023
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	9/30/2021 VD	10/1/2021 VD 00:18
Client Sample Description	13FD BSMT Boys Gym Bathroom Sink	Collected:	9/1/2021 9:35:00 AM	Lab ID:	012110578-0025
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.56	1.00 µg/L	9/30/2021 VD	10/1/2021 VD 00:26
Client Sample Description	14FD BSMT Cafeteria Kitchen Sink	Collected:	9/1/2021 9:35:00 AM	Lab ID:	012110578-0027
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.04	1.00 µg/L	9/30/2021 VD	10/1/2021 VD 00:27
Client Sample Description	15 Field Blank	Collected:	9/1/2021 9:35:00 AM	Lab ID:	012110578-0029
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	9/30/2021 VD	10/1/2021 VD 00:29



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077
Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order:	012110578
CustomerID:	OMEG50
CustomerPO:	21-26072
ProjectID:	

Definitions:

MDL - method detection limit
J - Result was below the reporting limit, but at or above the MDL
ND - indicates that the analyte was not detected at the reporting limit
RL - Reporting Limit (Analytical)
D - Dilution Sample required a dilution which was used to calculate final results

Order ID: 012110578



Lead Chain of Custody
EMSL Order Number / Lab Use Only

EMSL Analytical, Inc
200 Route 130 North
Cinnaminson, NJ 08077

012110578

PHONE (800) 220-3675
EMAIL Cinnaminson.lab@emsl.com

EMSL ANALYTICAL, INC.
TESTING LABS - PRODUCTS - TRAINING

Customer Information		Billing Information	
Customer ID:	Company Name: Omega Environmental	Billing ID:	Company Name: Omega Environmental
Contact Name:	Street Address: 280 Huyler Street	Billing Contact:	Street Address: 280 Huyler Street
City, State, Zip: S Hackensack, NJ 07606	Country: USA	City, State, Zip: S Hackensack, NJ 07606	Country: USA
Phone: 201-489-8700	Email(s) for Report: Lab@omega-env.com, sarahh@omega-env.com	Phone: 201-489-8700	Email(s) for Invoice: ap@omega-env.com

Project Information

Project Name/No: Arch of Newark/ St. Joseph High Point School/ 21-26072

EMSL LIMS Project ID: (If applicable, Email via project)

US State where samples collected: NJ

State of Connecticut (CT) must select project location: Commercial (Taxable) Residential (Non-Taxable)

Sampled By Name: Sarah Hutchins

Sampled By Signature: *Sarah Hutchins*

Turn-Around-Time (TAT): 3 Hour 6 Hour 24 Hour 32 Hour 48 Hour 72 Hour 96 Hour 1 Week 2 Week

MATRIX	METHOD	INSTRUMENT	REPORTING LIMIT	SELECTION
CHIPS <input type="checkbox"/> by wt <input type="checkbox"/> ppm (weight) <input type="checkbox"/> mg/m ²	SW 846-7000B	Flame Atomic Absorption	0.008% (80ppm)	<input type="checkbox"/>
	SW 846-60100*	ICP-OES	0.0004% (4ppm)	<input type="checkbox"/>
	NIOSH 7082	Flame Atomic Absorption	4ppg/filter	<input type="checkbox"/>
AIR	NIOSH 7300M / NIOSH 7303M	ICP-OES	0.5ug/filter	<input type="checkbox"/>
	NIOSH 7300M / NIOSH 7303M	ICP-MS	0.05ug/filter	<input type="checkbox"/>
WIPE <input type="checkbox"/> ASTM <input type="checkbox"/> non-ASTM	SW 846-7000B	Flame Atomic Absorption	10ug/wipe	<input type="checkbox"/>
	SW 846-60100*	ICP-OES	1.0ug/wipe	<input type="checkbox"/>
TCLP	SW 846-1311 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
	SW 846-1311 / SW 846-60100*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>
SPLP	SW 846-1312 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
	SW 846-1312 / SW 846-60100*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>
TTLIC	22 CCR App. II, 7000B	Flame Atomic Absorption	40mg/kg (ppm)	<input type="checkbox"/>
	22 CCR App. II, SW 846-60100*	ICP-OES	2mg/kg (ppm)	<input type="checkbox"/>
STLC	22 CCR App. II, 7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
	22 CCR App. II, SW 846-60100*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>
Soil	SW 846-7000B	Flame Atomic Absorption	40mg/kg (ppm)	<input type="checkbox"/>
	SW 846-60100*	ICP-OES	2mg/kg (ppm)	<input type="checkbox"/>
Wastewater Unpreserved <input type="checkbox"/> Preserved with HNO ₃ <input type="checkbox"/> PH-2 <input type="checkbox"/>	SM 3111B / SW 846-7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
	EPA 200.7	ICP-OES	0.020 mg/L (ppm)	<input type="checkbox"/>
Drinking Water Unpreserved <input type="checkbox"/> Preserved with HNO ₃ <input checked="" type="checkbox"/> PH-2 <input type="checkbox"/> <i>66 918</i>	EPA 200.5	ICP-OES	0.003 mg/L (ppm)	<input type="checkbox"/>
	EPA 200.8	ICP-MS	0.001 mg/L (ppm)	<input checked="" type="checkbox"/>
TSP/SPM Filter	40 CFR Part 50	ICP-OES	12 ug/filter	<input type="checkbox"/>
Other:				<input type="checkbox"/>

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
Samples begin on the following page			

Method of Spigotment	Sample Condition Upon Receipt
Relinquished by: Sarah Hutchins	Received by: <i>APRIL COURTESY</i>
Date/Time: 9/1/21 11:00	Date/Time: 9/2/21 8:15 pm
Relinquished by:	Received by: <i>EMSL 0710812</i>

Controlled Document - CQC-25 Lead R16 4/1/2017

*6010C Available Upon Request

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.



EMSL ANALYTICAL, INC.
 200 ROUTE 130 NORTH
 CINCINNATI, OH 45229

Lead Chain of Custody

EMSL Order Number / Lab Use Only
 012110578

EMSL Analytical, Inc.
 200 Route 130 North
 Cincinnati, NJ 08077
 PHONE: (800) 226-9875
 EMAIL: Cincinnati.lead.lead@emsl.com

***Only Test Flush Sample if the corresponding First Draw Sample Result > 15ppb** *OUTSIDE WATER SPIGOT INACCESSIBLE FOR SAMPLING, WATER SHUT OFF

Sample Number	Sample Location	Volume / Area	Date / Time Sampled	Note	
17	09 FD	1st Floor Main Office Bathroom Sink	250mL	9/11/21 10:05	
18	09 FL	"	"	10:05	
19	10 FD	1st Floor Nurse's Office Bathroom Sink	"	10:08	
20	10 FL	"	"	10:08	
21	11 FD	1st Floor Nurse's Office Room Sink	"	10:10	
22	11 FL	"	"	10:10	
23	12 FD	EMIS Gym BSMT APPROXIMATE Bathroom Sink	"	10:16	
24	12 FL	"	"	10:16	
25	13 FD	BSMT Boys Gym Bathroom Sink	"	10:18	
26	13 FL	"	"	10:18	
27	14 FD	BSMT Caterina Kitchen Sink	"	10:22	
28	14 FL	"	"	10:22	
29	15	Field Blank	"	11:00	

Order ID: 012110578

Method of Dispensing: _____

Sample Container Type/Receipt: _____

Requested by: Sarah Hutchins Date/Time: 9/11/21 11:00

Received by: _____ Date/Time: _____

Requested by: _____ Date/Time: _____

Received by: _____ Date/Time: _____



EMSL ANALYTICAL, INC.
 200 ROUTE 130 NORTH
 CRANFORD, NJ 07017

Lead Chain of Custody
 EMSL Order Number / Lab Use Only
 012110578

EMSL Analytical, Inc.
 200 Route 130 North
 Cranford, NJ 07017
 PHONE: (908) 220-3675
 EMAIL: cransford.leadlab@emsl.com

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)
 *Only test Flush Sample if the corresponding First Draw Sample Result > 15ppb *Signs Posted

Sample Number	Sample Location	Volume / Area	Date / Time Sampled	Notes
01 FD	2nd Floor Girls Bathroom Left Sink	250 mL	9/11/21 9:35	*Center - right sink in and floor girls BR not working
01 FL	" "		9:35	
02 FD	2nd Floor Boys Bathroom Right Sink		9:41	*left sink in and floor boys BR not working
02 FL	" "		9:41	
03 FD	2nd Floor Teacher's Lounge Room Sink		9:45	fixing valve
03 FL	" "		9:45	" "
04 FD	2nd Floor Teacher's Lounge Bathroom Sink		9:48	
04 FL	" "		9:48	
05 FD	1st Floor Girls Bathroom Left Sink		9:52	
05 FL	" "		9:52	
06 FD	1st Floor Girls Bathroom (center sink)		9:55	*Right sink in girls 1st floor BR not working
06 FL	" "		9:55	
07 FD	1st Floor Boys Bathroom Left Sink		9:58	
07 FL	" "		9:58	
08 FD	1st Floor Boys Bathroom Right Sink		10:00	
08 FL	" "		10:00	

Order ID: 012110578

Requested by: Sarah Hutchins
 Date/Time: 9/11/21 11:00
 Received by: _____
 Date/Time: _____